

EXTRACT

DESCRIPTION

FIRE TOWER, CLIMBED TO TOP TO SEE IF THERE IS A DIRECT LINE OF SIGHT TO WELL HOUSES
DEFINITELY NO LINE OF SIGHT

WATER TOWER, CLIMBED TO THE TOP TO SEE IF THERE WAS A LINE OF SIGHT TO THE WELL HOUSES,
NO LINE OF SIGHT, WAS TOLD TO TRY THE FIRE TOWER

WH 1, TESTED 6 INCH METER, WAS 100 % ACCURATE, TESTED IT THROUGH THE HYDRANT OUTSIDE

WH 2, TESTED 6 INCH METER, WAS 100 % ACCURATE, TESTED IT THROUGH THE HYDRANT OUTSIDE
HYDRANTS FLUSHED 72000 GALLONS

HYDRANTS FLUSHED 81000 GALLONS

HAACK, FINISHED INSTALL OF METER AND OUTSIDE READER

CRANE, INSTALLED ON CHEVY TRUCK AT TIMS HOUSE

KALEBIC, WATER LATERIAL WAS LEAKING IN WACKERS YARD, WE TURNED IT OFF, IT IS UP TO KALEBIC
AND WACKER TO SORT THROUGH IT

FILLED DUMPTER UP WITH METAL FROM HWY 17 PROJECT PILE AND LAID GRAVEL ON ROAD ALONG
WEST SIDE OF PONDS

FILLED 2ND DUMPSTER WITH METAL APROX 20,000 LB SOLD TO SALVAGE YARD

CMAR FOR JENNIFER SERVICING VISIT BY RURAL DEVELOPMENT TO PHELPS

FLYTT PUMP SCHOOL

COPPER SAMPLES, PICKED UP BOTTLES, FILLED OUT ALL THE PAPERWORK, AND DROVE THE SAMPLES
TO EAGLE RIVER TO THE FED EX DROP OFF STATION

LS3, PUMP 1 WAS CLOGGED WITH SOME RAGS, NEW CRANE WORKED AWESOME

MINUTES OF 10-5-2012 WILL BE POSTED ON TOWN WEB SITE WHEN AVAILABLE